



Display of Motorized Vehicles

Your Event Coordinator must be notified in advance if motorized vehicles are to be displayed during an event. Displayed motorized vehicles shall comply with the following and may also have to comply with additional rules and regulations required by the Fire Inspector.

Any use or storage of LPG/CNG is forbidden within the building unless approved by TFD.

Any vehicle within the buildings or within 20' of any building opening shall comply with the following regulations:

All vehicles must have a notice posted (form attached below) on the dashboard declaring that the battery supply has been disconnected and that the fuel tank has been reduced and sealed as follows:

- Vehicle fuel tanks shall not exceed one quarter of the tank capacity or 5 gallons (18.9 L) whichever is less
- All fuel tank openings shall be sealed in an approved manner to prevent escape of vapors (taped)
- The battery cables must be disconnected from the terminals and remain disconnected while the vehicle is inside the building. Loose cable ends must be taped to cover all the exposed metal
- No vehicle may be started or operated within any TCC building during show hours without approval of the Fire Inspector.
- Adding or removing fuel within any TCC building is prohibited. Fuel can be added outdoors, not under the canopy, in an approved location by the Fire Inspector. The use of special fuel blends inside the building is subject to approval by TFD.
- A vehicle key must be left in the Security Control Office for emergencies.

Fire protection shall be approved by TFD code official for motor vehicle shows/events. The level of protection required shall be determined for each event.





TEMPORARY PERMIT

INTERNAL COMBUSTION ENGINES USE

ISSUED DATE _____ EVENT _____

The Tucson Fire Code requires a permit for displaying an internal combustion engine for each motor vehicle, boat, aircraft or machinery. Display permit on passenger side window or dash.

The undersigned hereby agrees to abide by the Tucson Fire Code (TFC) as follows:

- 1) Fuel of any type shall be limited. Fuel, in fuel tanks, shall not exceed one quarter of a tank capacity or 5 gallons, whichever is less.
- 2) All fuel tank openings shall be sealed in an approved manner to prevent the escape of vapors.
- 3) Vehicles or equipment shall not be fueled or de-fueled within the building and only in approved location. Promoter shall provide spill containment materials and their proper disposal
- 4) The battery must be disconnected and remain disconnected while the vehicle is inside the building. Cable ends must be taped and all the exposed metal covered
- 5) LPG/CNG tanks shall be removed

	YES	NO
Visual Inspection for leaks		
Fuel Tank Sealed		
Keys on Site		
LPG Tank Removed		
Battery Disconnected, Leads Taped		
This Form Signed		

I certify that I have read the above Tucson Fire Code provisions and that any violation(s) will be grounds for possible civil infraction(s) and revocation of this permit. A revoked permit shall result in removal of the exhibit from the show floor immediately.

Exhibitor's Signature: _____ **Date:** _____

Contact Phone #'s: _____



Permit Requirements

Tucson Convention Center (TCC), or Tucson Fire Department (TFD), or Development Services Department (DSD) permits are required for the following:

- All motorized vehicle displays, i.e., auto shows or sales or motorized vehicle events, i.e., monster trucks, mud bogs, motorcycles, etc. (See “Display of Motorized Vehicles” below.)
- All indoor cooking. (See “Cooking and Warming Booths” above)
- Pyrotechnic displays. - Information and permits available from the Tucson Fire Department Fire Prevention Center.
- Air-supported temporary membrane structures or tents having an area in excess of 400 square feet or canopies having an area in excess of 900 square feet. (See “Structures and Exhibit Booths” below.) - Permits are issued @ 201 N. Stone at Developmental Services Department (DSD)
- Any tent larger than 400 sq. ft., or canopy larger than 900 sq. ft. shall require a permit be issued at 201 N. Stone at DSD

If there are any additional requirements not anticipated by these permits, they shall be determined by the fire inspector for each event.



INQUIRES TO:

Tucson Fire Prevention Center
797 E. Ajo Way, Tucson, AZ 85713
(520) 791-4502

Development Services Department
201 N. Stone, Tucson AZ 85701
(520) 791-5550.